

НОМЕР АБОНЕНТА:

Поддача#

Система 1

ТЭМ-104 Зав.Н 1561681

АДРЕС УСТАНОВКИ: г.Доброэ 2/4

G1 ДУВО 0.400 - 160.0 м3/ч

G2 ДУВО 0.400 - 160.0 м3/ч

Q = M1(tn - to)

ВЕДОМОСТЬ УЧЕТА ПАРАМЕТРОВ ТЕПЛОПОТРЕБЛЕНИЯ
за период с 20/09/16 по 19/10/16

ДАТА	Q	M1	M2	M1-M2	Tn	To	Pn	Po	Tнар,ч
дд/мм/гг	Гкал	т	т	т	С	С	МПа	МПа	час
20/09/16	6.25	296.8	298.3	-1.4	70.19	49.23	0.91	0.51	24.00
21/09/16	11.78	503.5	504.2	-0.7	71.08	47.77	0.91	0.51	24.00
22/09/16	15.18	454.5	455.0	-0.5	72.99	39.66	0.91	0.51	24.00
23/09/16	14.88	424.0	424.5	-0.5	74.01	38.98	0.91	0.51	24.00
24/09/16	14.27	448.0	448.7	-0.7	71.72	39.94	0.91	0.51	24.00
25/09/16	13.63	466.7	467.5	-0.8	70.13	41.01	0.91	0.51	24.00
26/09/16	15.48	560.0	560.4	-0.4	69.77	42.20	0.91	0.51	24.00
ИТОГО:	91.5	3153.4	3158.5	-5.1	71.38	42.46	0.91	0.51	168.0
27/09/16	18.85	687.7	686.5	+1.2	70.93	43.62	0.91	0.51	24.00
28/09/16	18.88	697.0	696.1	+0.8	71.05	44.04	0.91	0.51	24.00
29/09/16	18.52	739.7	736.8	+2.9	69.58	44.63	0.91	0.51	24.00
30/09/16	18.75	740.3	737.4	+3.0	70.04	44.79	0.91	0.51	24.00
01/10/16	19.34	745.6	742.8	+2.8	71.03	45.17	0.91	0.51	24.00
02/10/16	18.78	744.2	741.6	+2.6	70.51	45.35	0.91	0.51	24.00
03/10/16	18.34	757.8	755.2	+2.6	70.35	46.23	0.91	0.51	24.00
ИТОГО:	131.5	5112.4	5096.5	+15.9	70.49	44.86	0.91	0.51	168.0
04/10/16	18.66	757.5	754.8	+2.6	71.13	46.58	0.91	0.51	24.00
05/10/16	18.96	770.5	767.8	+2.7	71.39	46.87	0.91	0.51	24.00
06/10/16	19.56	866.0	863.1	+2.8	70.62	48.12	0.91	0.51	24.00
07/10/16	19.10	881.0	878.5	+2.4	70.04	48.44	0.91	0.51	24.00
08/10/16	18.79	861.8	859.3	+2.5	69.91	48.19	0.91	0.51	24.00
09/10/16	18.76	863.1	860.7	+2.4	69.65	47.99	0.91	0.51	24.00
10/10/16	18.79	847.8	845.2	+2.6	70.01	47.93	0.91	0.51	24.00
ИТОГО:	132.6	5847.5	5829.4	+18.1	70.36	47.77	0.91	0.51	168.0
11/10/16	7.38	338.7	337.7	+1.1	70.30	48.61	0.91	0.51	24.00
12/10/16	13.48	539.5	537.4	+2.1	72.14	47.23	0.91	0.51	24.00
13/10/16	_____	_____	_____	_____	_____	_____	_____	_____	_____
14/10/16	_____	_____	_____	_____	_____	_____	_____	_____	_____
15/10/16	_____	_____	_____	_____	_____	_____	_____	_____	_____
16/10/16	_____	_____	_____	_____	_____	_____	_____	_____	_____
17/10/16	_____	_____	_____	_____	_____	_____	_____	_____	_____
ИТОГО:	20.9	878.2	875.1	+3.2	71.43	47.76	0.91	0.51	48.0
18/10/16	_____	_____	_____	_____	_____	_____	_____	_____	_____
19/10/16	_____	_____	_____	_____	_____	_____	_____	_____	_____
ИТОГО:	0.0	0.0	0.0	+0.0	0.00	0.00	0.00	0.00	0.0
ИТОГО:	376.4	14991.6	14959.5	+37.2	70.68	45.65	0.91	0.51	552.0
		+32.1		-5.1	25.03				

Общее время работы системы, ч = Tнар. + Tmin + Tmax + Tdtmin + Tтн.
744.00 552.00 0.00 0.00 0.00 168.00

Количество тепла, Гкал Q = Qt/c + Qmin + Qmax + Qощ. + Qt/в + Qсан.ут.
_____ = 376.4 + _____ + _____ + _____ + _____ + _____

Показания интеграторов на	19/09/16 24:00	12/10/16 24:00	Разность	13/10/16 11:15
Расход тепла Q, Гкал	161.66	538.08	376.42	547.43
Расход теплоносителя M1, т	7833.2	22824.8	14991.6	23313.1
Расход теплоносителя M2, т	7913.1	22872.6	14959.5	23359.1
Время наработки Tнар, ч	1112.95	1664.94	552.00	1676.19
Время неработы Tнер = Tmax + Tmin + Tdt + Tтн, ч			168.00	

вЗА.10

Подпись потребителя _____



Подпись поставщика _____